

WATER MAIN BREAK

For up-to-date information regarding a water main break, please check the

[Ringwood DPW FaceBook Page](#):

After water service has been restored, the following measures are encouraged once the repairs have been completed:

- Run your water faucets for 3-5 minutes to flush your service connection and interior plumbing with water from the service main.
- Empty and clean your automatic ice makers and water chillers.
- Drain and refill your hot water heater if the temperature is set below 113 degrees Fahrenheit.
- Service connections with a water softener/cartridge filters should be run through a regeneration cycle or other procedures recommended by the manufacturer.
- Water reservoirs in tall buildings should be drained and refilled (as applicable).

We apologize for any inconvenience and thank you for your patience. If you have any questions or comments, please call the **Water Operator at 973-475-7133**.